



2 CONDUCTING ELECTRODE DETAIL

MINIMUM OF 20 FEET
 LONG OF #4-AWG BARE
 COPPER CONDUCTOR IN
 THE GRADE BEAM TO PIER,
 LOCATED TWO INCHES
 FROM THE BOTTOM OF
 THE GRADE BEAM

CONCRETE PIER # P-8

3 NOT USED

4 NOT USED

5 NOT USED

1 DETAIL @ CONC. PIERS & GRADE BEAMS

6 NOT USED

7 NOT USED